

FALL PROTECTION			
Contract Name and Number:		Contractor/Subcontractor:	
Government Inspector:		Location:	
Contractor Inspector:		Date:	
	Yes	No	N/A
1. Is each employee who might be exposed to fall hazards trained by a competent person qualified in the following areas, in the safe use of accessways and fall protection systems and the recognition of hazards related to their use? (21.A.16a)			
2. Are the manufacturer's recommendations followed in the fitting, adjustment, use, inspection, testing, and care of personal fall protection equipment? (21.C.06)			
3. Is personal fall protection equipment inspected before use each day to determine that it is in safe working condition? (21.C.07)			
4. Are body belts prohibited from use (except as positioning devices)? (05.F.01b)			
5. Are ropes and straps (webbing) used in lanyards, lifelines, and strength components of body belts and body harnesses made from synthetic fibers? (05.F.03d)			
6. When vertical lifelines are used, is each employee attached to a separate lifeline? (21.C.09a)			
7. Are anchorages used for attachment of personal fall arrest equipment independent of any anchorage used to support or suspend platforms and are they capable of supporting at least 2,270 kg (5,000 lb) per employee attached? (21.C.10a)			
8. Are safety nets in place and tested before operations requiring safety net protection are undertaken? (21.C.11c)			
9. Prior to commencing any activity which requires work in elevated areas, have all provisions for access and fall protection been delineated in the hazard analysis and accepted by the designated authority? (22.A.03)			
10. Is each person supported by a suspended scaffold protected by a Type I body belt or body harness system? (22.E.15a)			
11. Are workers provided fall protection whenever they are exposed to falls of 1.8 m (6 ft) or more? (27.E.06)			
Comments:			

This checklist is based on EM 385-1-1, dated 3 September 1996. Use of this checklist is optional.